



# EVPÚ<sup>®</sup>

## CERTIFICATE No. 00114/101/1/2017

on October 31<sup>st</sup>, 2017

Certification body of EVPÚ a.s. confirms the compliance of the product with requirements of undermentioned standards.

Product: **Indoor Emergency Lightings**

Type: **Elix**

Specification: **230V AC, 50Hz, 5W, IP20, +5°C - +45°C**

Client: **PARADOX HELLAS S.A. - OIKONOMIDIS P. SECURITY SYSTEMS S.A.,  
3 Korinthou str, 14451 Metamorfofi, Attiki, Greece**

Manufacturer: **PARADOX HELLAS S.A. - OIKONOMIDIS P. SECURITY SYSTEMS S.A.,  
69<sup>th</sup> Klm of N.R. Athens - Lamia, 32009 Vrises Ritsonas, Greece**

Standards: **EN 60598-1: 2015,  
EN 60598-2-22: 2014,  
EN 62031: 2008 + A1: 2013 + A2: 2015,  
EN 62471: 2008,  
EN 61347-1: 2008 + A1: 2011,  
EN 61347-2-7: 2012,  
EN 61347-2-13: 2014 + A1: 2017,  
EN 55015: 2013 + A1: 2015,  
EN 61547: 2009**

Results of tests of mentioned product are summarized in Final report on assessment No. **0-0525/17/C** of **October 31<sup>st</sup>, 2017**.

Used standards are harmonized with directives of the European parliament and of the Council 2014/35/EU transposed into Slovak government decree No. 148/2016 Z. z. and 2014/30/EU transposed into Slovak government decree No. 127/2016 Z. z.

Validity of certificate  
is limited for the period  
from: **October 31<sup>st</sup>, 2017**  
until: **October 30<sup>th</sup>, 2020**



Marek H u d á k

Any significant changes in the design or construction of the products or amendments of the technical decrees reference above may render this Certificate invalid. The product liability rests with the manufacturer or his representative.

EVPÚ a.s., Trenčianska 19, 018 51 Nová Dubnica, Slovak republic, [www.evpu.sk](http://www.evpu.sk)

052436

Page 1 / 1 F COCV 7.7.9