



CERTIFICATE

No. 00066/101/1/2024

on November 25th, 2024

Certification body of EVPÚ a.s. confirms the compliance of the products with requirements of undermentioned standards.

Product: **Advanced Conventional Fire Alarm Control Panel**

Type: **NEON 8, NEON 4, NEON 2**

Specification: **230VAC, 50Hz, 1A**

Client/ Manufacturer: **PARADOX HELLAS S.A. - OIKONOMIDIS P. SECURITY SYSTEMS S.A.,
3 Korinthou str., Metamorfosi, 14451 Attiki, Greece**

Identification Code: **EL094517180**


Manufacturing facilities: **PARADOX HELLAS S.A. - OIKONOMIDIS P. SECURITY SYSTEMS S.A.,
69th Klm of N.R.Athens – Lamia, 32009 Vrises Ritsonas, Avlida, Greece**

Standards: **EN 62368-1: 2020 + A11: 2020
EN 55032: 2015 + A1: 2020 + A11: 2020
EN IEC 61000-3-2: 2019 + A1: 2021 +A2: 2024
EN 61000-3-3: 2013 + A1: 2019 + A2: 2021
EN 50130-4: 2011 + A1: 2014**

Results of tests of mentioned products are summarized in Final report on assessment No. **0-0221/24/C** of **November 25th, 2024**.

Used standards are harmonized with directives of the European parliament and of the Council 2014/35/EU transposed into Slovak government decree No. 148/2016 Z. z. and 2014/30/EU transposed into Slovak government decree No. 127/2016 Z. z.

Validity of certificate is limited for the period
from: **November 25th, 2024**
until: **November 24th, 2027**



Michal Mišiak

Any significant changes in the design or construction of the products or amendments of the technical decrees reference above may render this Certificate invalid. The product liability rests with the manufacturer or his representative.

EVPÚ a.s., Trenčianska 19, 018 51 Nová Dubnica, Slovak republic, www.evpu.sk

Page 1 / 1 F COCV 7.7.9 Rev.2

056243